

ADDENDUM NO. 1
TO PLANS, SPECIFICATIONS AND CONTRACT DOCUMENTS

TO: ALL PLANHOLDERS AND PROSPECTIVE BIDDERS

FOR: RALSTON PUBLIC SCHOOLS
SEYMOUR ELEMENTARY SCHOOL
LRA JOB NO. 0109114.01-021/321

OWNER: RALSTON PUBLIC SCHOOLS

ENGINEER: LAMP, RYNEARSON & ASSOCIATES, INC.
14710 WEST DODGE ROAD, SUITE 100
OMAHA, NEBRASKA 68154-2027

DATE: MAY 10, 2010

The following changes, corrections, clarifications and additions shall be made to the Plans, Specifications, and Contract Documents for the above-named project and shall be as binding as if incorporated in the original Contract Documents. The Contractor shall acquaint himself with all aspects of this Addendum.

All other provisions and stipulations of the Contract Documents remain in effect, as originally issued.

The Contractor shall acknowledge receipt of all addenda on the Proposal Form.

The following shall be deleted, modified or added to as follows:

PLANS

1. Sheet 7 of 8 - Flag note #5 – clarification: Contractor shall provide shop drawing submittal for lighting relay panel. Contractor shall provide owner training for operation and programming of relay panel. If any specialized equipment / software is required to program the relay panel, the contractor shall provide the district with that equipment / software. Contractor shall verify programming with owner. Greengate LK8 shall be considered as equal to product specified.
2. Sheet 8 of 8 - The following fixtures shall be considered as equal to those specified in the light fixture schedule subject to compliance with Omaha Lighting ordinance (calculations to be included with fixture submittal)
'A' – Invue EXM series
'B' – Invue EXM series

END OF ADDENDUM

Sincerely,

LAMP RYNEARSON & ASSOCIATES, INC.



Patrick C. Hillyer, P.E., LEED® AP
Senior Project Engineer