

ADDENDUM No. 1
TO PLANS, SPECIFICATIONS AND CONTRACT DOCUMENTS

TO: ALL PLANHOLDERS AND PROSPECTIVE BIDDERS

FOR: STORM SEWER SECTION II – BOX CULVERTS
(SCHEWE FARMS)
LRA JOB NO. 0109050.11-041

OWNER: SANITARY AND IMPROVEMENT DISTRICT NO. 290

ENGINEER: LAMP, RYNEARSON & ASSOCIATES, INC
14710 West Dodge Road, Suite 100
Omaha, Nebraska 68154-2027

DATE: APRIL 29, 2010

The following changes, corrections, clarifications and additions shall be made to the Plans, Specifications, and Contract Documents for the above-named project and shall be as binding as if incorporated in the original Contract Documents. The Contractor shall acquaint himself with all aspects of this Addendum.

All other provisions and stipulations of the Contract Documents remain in effect, as originally issued.

The Contractor shall acknowledge receipt of all addenda on the Bid Form.

The following shall be deleted, modified or added to as follows:

CONTRACT DOCUMENTS

1. The bid item tables in the Notice to Contractor, Bid Form, Sample Agreement and Contractor's Application for Payment have been revised from that published for advertising.
2. The following shall be added to the Contract Documents in the Technical Specifications as Section A.2.09:
 - 2.09 Sealant
 - A. The work described in these Technical Specifications shall consist of applying a concrete sealant coating on the exposed, colored areas of the segmental block retaining walls of the box culverts on Ballpark Way West, Lincoln Road West and Lincoln Road East.
 - B. Sealant: The Sealant shall be as specified by the wall block manufacturer and shall be compatible with the color scheme being used and with the application of an anti-graffiti coating. The sealant shall be applied before the anti-graffiti

coating, and shall provide protection to the colored surface of the wall blocks to prevent or reduce the occurrence of fading.


- C. Segmental Walls: The segmental block walls shall be cast with an integral color. The final color scheme is to be as per Section 2.01 H of the specification. Any necessary repairs to the wall will need to be made to the satisfaction of the OWNER of any damaged surfaces prior the application of the sealant. Surfaces to be coated include the exposed front surface of the wall, the front, back, ends and sides of the dual faced blocks, and all exposed surfaces of the top block units.
- D. Application: The Contractor shall follow all required surface preparations, use of equipment, containment materials, materials storage, protection of surrounding surfaces, cleanup, mixing, handling, thinning, quality control, disposal and application of the materials as recommended by the Coating Manufacturer. Coatings must be applied during favorable temperature, humidity and other weather conditions as per the Coating Manufacturer's required conditions. The Contractor shall provide verification that the quality of surface preparation and product application are satisfactory for the wall block and concrete system.

The following shall be added to the Contract Documents in the Technical Specifications as Paragraph D of Section A.5.01:

- D. Measurement for sealant shall be final colored, exposed areas of walls around the culvert headwalls as measured and calculated in the field as "Sealant", square feet (SF). Payment shall be full compensation for furnishing, preparing and placing the sealant and other component materials, and for all equipment, tools and incidentals necessary to complete the work of coating the walls.

END OF ADDENDUM

LAMP, RYNEARSON & ASSOCIATES, INC.


Johnny M. Hill, P.E.
Structural Department Manager

