

ADDENDUM NO. 2
TO PLANS, SPECIFICATIONS AND CONTRACT DOCUMENTS

TO: ALL PLANHOLDERS AND PROSPECTIVE BIDDERS

FOR: SANITARY & IMPROVEMENT DISTRICT NO. 290
(SCHEWE FARMS - WATER, SECTION I)
LRA JOB NO. 0109050.11-060/360

OWNER: S.I.D. NO. 290 OF SARPY COUNTY, NEBRASKA

ENGINEER: LAMP, RYNEARSON & ASSOCIATES, INC.
14710 WEST DODGE ROAD, SUITE 100
OMAHA, NEBRASKA 68154-2027

DATE: JUNE 14, 2010

The following changes, corrections, clarifications and additions shall be made to the Plans, Specifications, and Contract Documents for the above-named project and shall be as binding as if incorporated in the original Contract Documents. The Contractor shall acquaint himself with all aspects of this Addendum.

All other provisions and stipulations of the Contract Documents remain in effect, as originally issued.

The Contractor shall acknowledge receipt of all addenda on the Proposal Form.

The following shall be deleted, modified or added to as follows:

PLANS

Sheet 3 of 16 – Modify "PVC/HDPE Bedding Detail" to be only **6" minimum** above top of water main.

CONTRACT DOCUMENTS


1. Delete Paragraph 126-06 Section 2-2.1, Sheet TS-62. Replace with "All water main shall be plastic pipe in accordance with AWWA C900 DR18 specifications."

ENCLOSURES

END OF ADDENDUM

Sincerely,

LAMP, RYNEARSON & ASSOCIATES, INC.


Patrick C. Hillyer, P.E., LEED® AP
Senior Project Engineer